

Visqueen TorchOn Tanking Membrane

BBA cert 14/5121

Page 1 of 4



- | **Robust tanking membrane**
- | **Suitable for gas protection applications**
- | **Torch bonded laps provide a homogenously sealed junction**
- | **Ideal for cold weather application**
- | **Used to waterproof basements, car parks, lift pits, reinforced concrete slabs, retaining walls**



EN 13969
 Type A and T

13

Description

Visqueen TorchOn Tanking Membrane is a robust waterproofing membrane, used for heavy duty tanking and gas proofing applications. It can be used both vertically and horizontally above and below ground level to prevent the ingress of water. Visqueen TorchOn Tanking Membrane should be used with Visqueen HP Tanking Primer on touch dry concrete. Substrates should be primed with Visqueen HP Tanking Primer prior to application. Visqueen TreadGUARD1500 should be used horizontally or for external vertical applications Visqueen Protect&Drain should be used to protect the membrane from backfill or site traffic.

Application

Visqueen TorchOn Tanking Membrane should be applied as a two layer system when used as a tanking system for below ground structures where high levels of hydrostatic (water) pressure exist in conjunction with an internal waterproof render in accordance with BS8102: 2009 type A structures. Visqueen TorchOn Tanking Membrane can be used as a single layer system when used as a horizontal damp proofing membrane or in low risk situations. All laps should be a minimum of 150mm. The loading screed or floor slab which is laid on top of the membrane should be adequate to resist any hydrostatic water pressure.

Additional System Components

- | [Visqueen HP Tanking Primer](#) (5L tin) – for preparation of touch dry concrete and masonry surfaces prior to application of the membrane. Coverage rate on concrete is about 6 - 8m² per litre. Drying time is 2-8 hours depending on temperature and ventilation.
- | [Visqueen TreadGUARD1500](#) - for protecting the membrane from damage during backfilling, etc
- | [Protect&Drain](#) - for protecting the membrane from damage during backfilling, etc
- | [Visqueen Zedex DPC Jointing Tape](#) for bonding Visqueen TreadGUARD1500 to Visqueen TorchOn Tanking Membrane.

VISQUEEN
 BUILDING PRODUCTS

Heanor Gate, Heanor, Derbyshire DE75 7RG

T: 0845 302 4758 F: 0845 017 8663

enquiries@visqueenbuilding.co.uk

www.visqueenbuilding.co.uk

VISQUEEN BUILDING PRODUCTS IS A TRADING NAME
 OF BRITISH POLYTHENE LIMITED, COMPANY NUMBER:
 350729, REGISTERED OFFICE: ONE LONDON WALL,
 LONDON, EC2Y 5AB

STRUCTURAL WATERPROOFING
 AND GAS PROTECTION SYSTEMS

Visqueen TorchOn Tanking Membrane

BBA cert 14/5121

Page 2 of 4

Installation

Preparation

Ensure that the surface to be treated is smooth, clean, dry, free from loose particles and is frost free. Concrete and renders should be completely cured. Unrendered masonry must be flush pointed. Installation should be in accordance with the recommendation of BS 8102:2009. A suitable drainage system should be designed and incorporated in accordance with the requirements of BS8102:2009.

Priming

All surfaces should be sealed using Visqueen HP Tanking Primer applied by brush, broom or roller. On concrete or masonry surfaces, coverage rate is about 6 - 8m² per litre. Ensure the primer is fully dry before application of the membrane. Drying time is 1 - 5 hours depending on temperature and ventilation. The newly applied primer should be protected from contamination.

Angles and corners

Provide a 50mm – 75mm sand/cement fillet. Reinforce all changes of direction with a 350mm strip of Visqueen TorchOn Tanking Membrane applied equidistant across the junction.

Setting out

When applying a two layer system, the membrane should be set out with staggered laps between first and second layers.

Lap joints

All side and end laps to be minimum 150mm. All lap joints should be fully bonded; a bead of bitumen should extrude from the joint.

Equipment and bonding

The membrane must be fully bonded to the prepared substrate using the gas torch-on technique. For horizontal work, an approximate 500mm neck tube and 50mm diameter propane gas burner should be used and for vertical and detailing work, an approximate 200mm neck tube and 35mm diameter propane gas burner is appropriate. During bonding, ensure that a constant flow of bitumen is maintained across the full width of the roll and that a bead of bitumen is extruded from each edge demonstrating that a correct seal has been obtained.

Horizontal bonding

Unroll and position the membrane. Roll back half way and starting from the middle of the roll, progressively roll forward whilst activating the coating on the underside of the roll. Repeat for the second half of the roll. Subsequent rolls should be set out with staggered end laps.

Vertical bonding

Cut the membrane to the appropriate length and position at the base of the wall. Progressively torch apply to the substrate working up the wall. Complete the vertical application by torch bonding the remainder of the membrane to the horizontally bonded membrane.

Protection and support

In external tanking situations or where there is a risk of damage, Visqueen TreadGUARD1500 should be positioned over the membrane. When bonding of the boards is required, attach with strips of Visqueen Zedex DPC Jointing Tape. Internal vertical tanking requires the construction of an internal leaf of masonry to provide support for the membrane. A cavity of a minimum of 50mm must be left which is progressively filled with sand/cement mortar as work proceeds. When the vertical membrane terminates, the uppermost end should be batten fixed or sealed into a chase. Internal horizontal tanking requires loading with sand/cement screed sufficient to resist hydrostatic water pressure.

SPECIFICATION SUPPORT

The following items are available to view online or to download from www.visqueenbuilding.co.uk

- . Technical Datasheets
- . Typical installation CAD details
- . Health and Safety data

Register online for access to NBS Clauses and for information about our CPD Seminars



TECHNICAL SUPPORT

For advice on detailing or installation call Visqueen Building Products Technical Help Line 0845 302 4758. Pricing & Availability may be obtained from our UK Network of merchant stockists. For details of these call our Sales Office on 0845 302 4758.


VISQUEEN
BUILDING PRODUCTS

Visqueen TorchOn Tanking Membrane

BBA cert 14/5121

Page 3 of 4

Continuity

Installation must ensure continuity of the tanking system around obstructions such as stanchions and pile caps and the formation of a minimum of 100mm bonded lap with the damp proofing system above ground level.

Storage and handling

Visqueen TorchOn Tanking Membrane must be stored on end and kept dry. The membrane is classified as non-hazardous when used in accordance with the relevant British Standard Code of Practice. Visqueen HP Tanking Primer should be stored in its original unopened container in a cool, dry area. Suitable Personal Protective Equipment (PPE) should be worn when using these materials and suitable fire fighting equipment must be available. Adequate ventilation must be ensured at all times during application. Ensure that hazardous ground gas levels are suitably diluted to prevent risk of explosion during membrane application. This must be addressed as part of the Hot Works Permit and Method Statement procedures. See health & safety datasheets available at www.visqueenbuilding.co.uk.

SPECIFICATION SUPPORT

The following items are available to view online or to download from www.visqueenbuilding.co.uk

- . Technical Datasheets
- . Typical installation CAD details
- . Health and Safety data

Register online for access to NBS Clauses and for information about our CPD Seminars



TECHNICAL SUPPORT

For advice on detailing or installation call Visqueen Building Products Technical Help Line 0845 302 4758. Pricing & Availability may be obtained from our UK Network of merchant stockists. For details of these call our Sales Office on 0845 302 4758.

VISQUEEN
BUILDING PRODUCTS

Visqueen TorchOn Tanking Membrane

BBA cert 14/5121

Page 4 of 4

Technical Data and CE Mark

Visqueen TorchOn Tanking Membrane complies with the requirements and clauses of EN 13969 - Flexible sheets for waterproofing. Bitumen damp proof sheets including bitumen basement tanking sheets.

MDV = Manufacturer's Declared Value
MLV = Manufacturer's Limiting Value



EN 13969
Type A and T

13

Product Data				
Characteristic	Test method	Units	Compliance criteria	Value or statement
Visible defect	EN 1850 -2	-	Pass/Fail	Pass
Length	EN 1848-2	m	-5%/+5%	8
Width	EN 1848-2	m	-5%/+5%	1
Mass	EN 1849-2	kg/m ²	+/-10%	4.5
Straightness	EN 1848-2	-	Pass/Fail	Pass
Thickness	EN 1849-2	mm	+/-10%	3.5
Watertightness 60kPa	EN 1928	-	Pass/Fail	Pass
Durability (artificial ageing)	EN 1296 and EN 1928	-	Pass/Fail	Pass
Durability (heat ageing)	EN 1296	-	Pass/Fail	Pass
Water vapour transmission properties	EN 1931	kg/ (m ² s)	+/-20%	5.79 x 10 ⁻⁶
Resistance to static loading	EN 12730	Kg	>MLV	>20
Reaction to fire	EN 13501-1		Class	F
Flexibility at low temperature	EN 12317-1	oC	MDV	-15
Tensile properties - MD	EN 12311-1	N/50mm	+/-20%	900
Tensile properties - CD	EN 12311-2	N/50mm	+/-20%	900
Tensile Elongation - MD	EN 12311-1	%	+/-20%	35
Tensile Elongation - CD	EN 12311-2	%	+/-20%	35

The information given in this datasheet is based on data and knowledge correct at the time of printing. Statements made are of a general nature and are not intended to apply to any use or application outside any referred to in the datasheet. As conditions of usage and installation are beyond our control we do not warrant performance obtained but strongly recommend that our installation guidelines and the relevant British Standard Codes of Practice are adhered to. Please contact us if you are in any doubt as to the suitability of application.